



Tennessee Valley Authority, 1101 Market Street, Chattanooga, Tennessee 37402-2801
May 28, 2002

Mr. Ralph Lewis
Mr. Doug Yanow
Power Research Inc.
3750 Hacienda Blvd., Suite A
Ft. Lauderdale, FL 33314

Gentlemen:

An annual sampling and testing of the fuel oil in tanks located at our Allen Turbine facility in Memphis, Tennessee revealed that the fuel oil stability in one of the tanks had deteriorated to a 17 Pad Rate.

1.8 million gallons of fuel has been fully treated with PRI-D as per its specifications, and we have re-sampled the tank and tested the fuel. The Dupont Pad rating with PRI-D treated fuel went from a 17 to a 3, fully meeting TVA specifications.

Sincerely yours,

A handwritten signature in black ink, appearing to read 'Lilian Bruce'.

Lilian Bruce
Fuel Supply Analyst